

Map ID  
Direction  
Distance  
Elevation

MAP FINDINGS

EDR ID Number  
EPA ID Number

1320  
North  
> 1  
1.688 mi.  
8912 ft.

**BOILER ROOM**  
**420 KINGS WALK**  
**BROOKLYN, NY**

**NY Spills S108955814**  
**N/A**

**Relative:**  
**Higher**

**Actual:**  
**25 ft.**

**SPILLS:**

Name: BOILER ROOM  
Address: 420 KINGS WALK  
City,State,Zip: BROOKLYN, NY  
Spill Number/Closed Date: 0707835 / 2007-10-17  
Facility ID: 0707835  
Facility Type: ER  
DER Facility ID: 338154  
Site ID: 388612  
DEC Region: 2  
Spill Cause: Equipment Failure  
Spill Class: C4  
  
SWIS: 2401  
Spill Date: 2007-10-17  
Investigator: smsanges  
Referred To: Not reported  
Reported to Dept: 2007-10-17  
CID: 444  
Water Affected: Not reported  
Spill Source: Commercial/Industrial  
Spill Notifier: Other  
Cleanup Ceased: Not reported  
Cleanup Meets Std: False  
Last Inspection: Not reported  
Recommended Penalty: Not reported  
UST Trust: Not reported  
Remediation Phase: 0  
Date Entered In Computer: 2007-10-17  
Spill Record Last Update: 2007-10-18  
Spiller Name: CHARLES MCINNIS  
Spiller Company: BOILER ROOM  
Spiller Address: 420 KINGS WALK  
Spiller Company: 001  
Contact Name: CHARLES MCINNIS  
DEC Memo: "3PM Sangesland spoke to Charles McInnis of Housing Authority. He said the cleanup was done by his people. 75 gallons to basement floor, 3 gal to sump pit. No oil was released to the soil or outside. Cleanup is complete Frank Inoa - Asst Super confirmed that the cleanup is complete."

Remarks: "BROKEN NIPPLE ON BOILER AND IN PROCESS OF CLEANING"

**All Materials:**

Site ID: 388612  
Operable Unit ID: 1145772  
Operable Unit: 01  
Material ID: 2136108  
Material Code: 0001A  
Material Name: #2 fuel oil  
Case No.: Not reported  
Material FA: Petroleum  
Quantity: 78.00  
Units: G  
Recovered: .00  
Oxygenate: Not reported